

	A	B	C	D	E
1	ITEM TESTED	AMP CLAMP	3 POINT	FRANKENSTEIN	
2	0.444				
3					
4	SOUTH MAINS ROOM		5.1		
5	MCC EM1			0.005	
6					
7	TRANSFER SW			0.01	
8					
9	MAINS CAB			0.005	
10					
11	AIR COMPRESSOR			0.03	
12					
13	BIG PLC CABINET		5.6	0.01	
14					
15	WEST SERVICE XFMR 4160 STEP UP			0.01	
16					
17	EAST SERVICE XFMR			0.01	
18					
19	AIR COND		4.5	0.11	
20					
21	RWTP 1		4.3	0.01	
22					
23	RWTP 2		4.3	0.01	
24					
25	RWTP 3		4.3	0.01	
26					
27	RWTP 4		4.3	0.01	
28					
29	AIT-2030-1A		5.4	0.096	
30					
31	AIT-2030-1B		5.5	0.01	
32					
33	RAW WATER PRESSURE 1-2		4.6	0.01	
34					
35	GENERATOR MASTER XFER		5.3	0.01	
36					
37	GENERATOR FRAME		3.8	0.02	
38					
39	AHU-3A			0.036	
40	CONDENSOR		5	0.06	

	A	B	C	D	E
41	AHU 3B			0.05	
42	CONDENSOR		4.9	0.06	
43	XFMR TRLS2			0.02	
44					
45	MAINS ROOM		5.9		
46					
47	MAINS SWITCH LSWBD-LS2			0.01	
48					
49	VFD 101			0.01	
50					
51	VFD 102			0.01	
52					
53	VFD 103			0.01	
54					
55	VFD 104			0.01	
56					
57	MCC-LS2			0.04	
58					
59	I-LS-1			0.01	
60					
61	C-LS-1			0.01	
62					
63	LP-LS-1			0.01	
64					
65	PC/TC-LS-1			0.01	
66					
67					
68	FIT 20420		9.3		
69					
70	LE-LIT-20500		9.7		
71					
72	AIT-20430A		10.1		
73					
74	AIT-20430B		9.7		
75					
76	HSP 4,5,6		6.6		
77					
78	FIT 20030		6.4		
79					
80	PIT 20030		6.1		
81					
82	AIR VOLUME CONT		5.6		
83					
84	FILTER S 20201		46.2	NEEDS CLEANING	
85					

	A	B	C	D	E
86	FILTER S20202		6.7		
87					
88	PIT 20400A		4.6		
89					
90	PIT 20400B		8.7		
91					
92	PIT 20400 CONTROLLER		5.6		
93					
94	FE/FIT 2100		5.4		
95					
96					
97					
98					
99					
100					
101	WELL 5		4.1		
102					
103					
104					
105	WELL 7		3.2		
106					
107	WELL 8		2.6		
108					
109	WELL 9		7.1		
110					
111	WELL 10		2.2		
112					
113	LS STRIPPER		XXX	PUMP IS UNGROUNDED	
114	SERVICE DISCONNECT		4.6		
115					
116	WELL 11		3.8		
117					
118	WELL 12		4.5		
119					
120	WELL 13		5.4		
121					
122	WELL 14		2.4		